

FORMAT FOR PRICE - BID

Sl.No	Material Description	Qty	Unit	HSN CODE	Basic Unit Price	GST on basic unit price		P&F chgs. (if any per Unit)in %	P&F chgs. Amount in Rs. Per Unit	GST on P&F		Freight charges per Unit (if any)	GST on freight		Other Charges, if any per unit (Rs.)	GST on other charges		Tot P
					(in Rs.)	(in %)	(in Rs.)		(In Rs.)	(in %)	(in Rs.)		(in %)	(in Rs.)	(in Rs.)	(in %)	(in Rs.)	(in fig)
1	FP 05 Firestop board, Fire rating: 2 Hrs, Fire Barrier system is having high density Mineral wool, Dimension: 1200mm x 600mm x 50mm. Test: UL 1479 02 hrs T&F rating, FM approved, GB23864, ASTM E84, ASTM E662, Make: INCA/ Hitech sealing and Insulating Industrieis	50	Sq.Mtr															
2	Mortar CFS01, Non Intumescent compound comprised of gypsum and cement. Test: UL 1479 03 hrs T&L rating, G23864, Make: INCA/ Hitech sealing and Insulating Industrieis	100	Kgs															
3	DC 6150 cable coating. Specifications: colour: white, Odour: Mild Latex, Gloss lavel: Matt, Specific gravity: 1.5 +-0.01, solid by weight: 70-76%, pH value: 6-8, Drying time: Deprndng on ambient condition, Dry to touch: 2-4 hrs, Dry through: 2-4 days, Application Airless spray, brush or roller, typical thickness: 1000 micron DFT (39.5 Mils) equivalent to 640 micron DFT (25 Mils) 25kgs/ pail. Test: FM approval class: 3971, IEEE 383, IEC60332-3A, IEEE1202, Make: INCA/ Hitech sealing and insulating industries	225	Kgs															

Note: Calibration certificate to be provided alongwith material.