

SPARE PARTS FOR KILBURN MAKE NON FLAMEPROOF GATE END BOX

Sl#	Material Code	Material Description	Qty. (Nos.)
1	300064094122	INSULALTOR CAP/KEEP PLATE PT NO. 7347	70
2	300064094123	INSULALTOR CAP/KEEP PLATE PT NO. 7359	70
3	300064094453	OVERLOAD ASSEMBLY P/NO.- FLP/CS-33	15
4	300064094476	PULLING MECHANISM PT.NO.- 7362	30
5	300064094591	PLUG INSULATOR PT NO. 7346	70
6	300064094594	PLUG & SOCKET RESTRAINED TYPE 4PIN 150AMPS PT.NO.- JI50PSF.	12
7	300064094606	MAIN CONTACT PIN PT NO. 7356	200
8	300064094607	PILOT CONTACT PIN PT NO. 7355	75
9	300064094710	PILOT RELAY COIL VOLTAGE 7.5 VOLTS PT.NO.: 7320/A.	15
10	300064094711	RUBBER RING P.NO.- 10044	150
11	300064094712	0 OHM 100 OHM 10 WATTS VARIABLE RESISTOR.	30
12	300064094846	MAIN CONATACT TUBE PT NO. 7348	200
13	300064094848	PILOT CONTACT TUBE PT NO. 7349	75

MAKE: KILBURN / OTHER MAKE.

1. Bidder Should submit their offer as per terms & conditions given under Annexure 1 2 & 3[ANNEXURE -1(Pre-Qualification Part) ANNEXURE-2(Technocommercial Cum Price Part) & Annexure -3 (Pre-Qualification Criteria)]
2. Please do not send your offer in hard copy. Bidder should submit their offer through our website i.e. [www.uraniumcorp.in](http://www.uraniumcorp.in) or [www.tenderwizard.com/UCILEPROC](http://www.tenderwizard.com/UCILEPROC) only.
3. Bidders of other makes shall confirm that these items will be suitably fitted in kilburn make Gate End Box.
4. Bidders of other makes may see sample at our site (please get in touch with Supdt. Elect.Mines Jaduguda for sample).

(S. N. KUMAR)  
DY. CONTROLLER OF S&P