



Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण		
Bid End Date/Time/बिड बंद होने की तारीख/समय	30-01-2025 21:00:00	
Bid Opening Date/Time/बिड खुलने की तारीख/समय	30-01-2025 21:30:00	
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	180 (Days)	
Ministry/State Name/मंत्रालय/राज्य का नाम	Pmo	
Department Name/विभाग का नाम	Department Of Atomic Energy	
Organisation Name/संगठन का नाम	Uranium Corporation Of India Limited	
Office Name/कार्यालय का नाम	Jaduguda	
Total Quantity/कुल मात्रा	830	
ltem Category/मद केटेगरी	Hydraulic Testing, Refilling, Painting and labelling of Fire Extinguisher, Tank Replacement, Valve Replacement, Carry Handle Replacement, Pressure Gauge Replacement, Safety Pin Replacement, Nozzle Replacement, Hose Replacement, Tamper Seal Replacement	
GeMARPTS में खोजी गई स्ट्रिंग / Searched Strings used in GeMARPTS	Refilling and Refurbishing of different types of industrial fire extinguishers	
GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS	Advance Fire Monitor (V2), Portable Fire Extinguishers (V2) as per IS 15683:2018, Hand Held Brush Cutter (V2), Wooden Podium, EXTINGUISHER FIRE DEFENCE WATER STORED AIR PRESSURE TYPE OF 9 LTRS CAPACITY (STAINLESS STEEL BODY)	
अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification	• Liquid Carbon Di oxide	
BOQ Title/बीओक्यू शीर्षक	REFILLING MAINTENANCE AND HYDRO TESTING OF FIRE EXTINGUSHIERS	
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No	
Startup Exemption for Turnover/ टर्नओवर के लिए स्टार्टअप को छ्न्ट प्राप्त है	Yes	

Bid Details/बिड विवरण		
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Experience Criteria,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer	
Do you want to show documents uploaded by bidders to all bidders participated in bid?/	Yes	
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No	
Type of Bid/बिड का प्रकार	Two Packet Bid	
Primary product category	Hydraulic Testing, Refilling, Painting and labelling of Fire Extinguisher	
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days	
Inspection Required (By Empanelled Inspection Authority / Agencies pre- registered with GeM)	Νο	
Estimated Bid Value/अनुमानित बिड मूल्य	342672	
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation	
Arbitration Clause	Νο	
Mediation Clause	No	

EMD Detail/ईएमडी विवरण

L			i I
			11
	Required/आवश्यकता	NO	11
L			11
			i

ePBG Detail/ईपीबीजी विवरण

Advisory Bank/एडवाइजरी बैंक	State Bank of India
ePBG Percentage(%)/ईपीबीजी प्रतिशत (%)	5.00
Duration of ePBG required (Months)/ईपीबीजी की अपेक्षित अवधि (महीने).	42

(a). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

Beneficiary/लाभार्थी :

Chief Manager A/Cs-WAS JADUGUDA, Department of Atomic Energy, URANIUM CORPORATION OF INDIA LIMITED, PMO (Posi Babu I)

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	No
MSE Purchase Preference/एमएसई खरीद वरीयता	
MSE Purchase Preference/एमएसई खरीद वरीयता	Yes

1. If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to their meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer. 2. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 OM No.1 4 2021 PPD dated 18.05.2023 for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

3. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

Excel Upload Required/एक्सेल में अपलोड किए जाने की आवश्यकता :

Price Format - <u>1732161750.xlsx</u>

Hydraulic Testing, Refilling, Painting And Labelling Of Fire Extinguisher

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	40	1095

Hydraulic Testing, Refilling, Painting And Labelling Of Fire Extinguisher

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./ सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	60	1095

Hydraulic Testing, Refilling, Painting And Labelling Of Fire Extinguisher

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document

	BOQ Detail Document	View File
--	---------------------	-----------

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	40	1095

Hydraulic Testing, Refilling, Painting And Labelling Of Fire Extinguisher

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती / रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	30	1095

Hydraulic Testing, Refilling, Painting And Labelling Of Fire Extinguisher

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	10	1095

Hydraulic Testing, Refilling, Painting And Labelling Of Fire Extinguisher

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/ਧਗ	Quantity/मात्र	Delivery Days/डिलीवरी वे दिन				
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	90	1095				
-	ydraulic Testing, Refilling, Painting And Labelling Of Fire Extinguisher echnical Specifications/तकनीकी विशिष्टियाँ							
Specifica	tion Document			iew File				
BOQ Det	ail Document			iew File				
		Q document for detailed consign Q document for detailed consign रेषिती/रिपोर्टिंग अधिकारी and/ तथा 0		y period.				
onsignee		Q document for detailed consign रेषिती/रिपोर्टिंग अधिकारी and/ तथा Q Address/पता		y period. Delivery Days/ डिलीवरी वे दिन				
onsignee S.No./丣.	es/Reporting Officer/प Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग	रेषिती/रिपोर्टिंग अधिकारी and/ तथा Q	Quantity/मात्रा	Delivery Days/डिलीवरी वे				

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	10	1095

Tank Replacement

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

s	.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1		Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	40	1095

Valve Replacement

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	60	1095

Carry Handle Replacement

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	60	1095

Pressure Gauge Replacement

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	60	1095

Safety Pin Replacement

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	60	1095

Nozzle Replacement

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	60	1095

Hose Replacement

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	60	1095

Tamper Seal Replacement

Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Rohith Kumar	832102,AT/PO-JADUGUDA MINES MAIN BUILDING URANIUM CORPORATION OF INDIA LTD	60	1095

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the

contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

PRE-QUALIFICATION CRITERIA (PQC)/ ELIGIBILITY CRITERIA

The followings are the Eligibility criteria for this Non-divisible service Contract. The bidder may visit the pro posed work site to get well acquaint about the site work before filling the rate/submit the tender.

1. PAST PERFORMANCE AND PROJECT / PAST EXPERIENCE etc. CRITERIA:

1.0 The Bidder have experience of Refilling/refurbishing/repairing/supply of different types industrial Fi re Extinguishers in last seven years with Govt. / PSU / Public Limited Organization / Private Limited Org anization.

2.0 Experience of **Similar Work** having successfully completed during the current or last 7 years endi ng last day of month previous to the one in which applications are invited.

<u>The "Similar Work" means Refilling/refurbishing/repairing/supply of different types industr</u> <u>ial Fire Extinguishers</u>

(Work Order Copy & Completion Certificate or PO copy with invoice should be attached as s upporting document)

2. FINANCIAL STANDING:

Average annual financial turnover during the last three financial years should be at least 30% of the yearly estimated Cost (1.03Lakh).

- 3. GSTIN copy & Make in India Declaration should be submitted along with the bid.
- 4. Any bid not complying PQC requirements shall be summarily rejected.
- 5. EMD exemption only to relevant MSME/MSE.
- 6. Turnover exemption only for relevant Startups as per government guidelines.

NOTE:

If the works are provided by the contractor in accordance with this contract, Corporation will pay the contr actor the price (awarded value); and reimburse the contractor for the approved expenses (as specified in t he order/ contract), after the approved expenses have been incurred by the contractor. Corporation will no t be liable to reimburse the contractor for expenses other than approved expenses, unless Corporation's p rior approved written consent.

The UCIL shall pay on reimbursement basis to the total applicable GST @ prevailing rate as per GST rule o n total transaction value (i.e. price actually paid to the service provider) after deduction of GST amount fr om the amount mentioned in the contract rate. GST on penalty, interest, non-related expenses and applic able GST on forfeiture of SD/ retention money/ EMD etc. shall not payable.


—

Scope of work

- Collection of the Fire Extinguishers from Bagjata Mines.
- · Dismantling, cleaning, overhauling of the Cylinder.
- Refilling/Gas Charging/Cartridge Replacement
- The quality of refilling to be ensured and there should be 3 months warranty after refilling.
- · Repair /Replacement of defective spare parts.
- Any other activity/work necessary to maintain the Fire Extinguisher as per instructions of Engineer In-Charge
- · Checking, Testing , ID Tagging
- Transporting to site.
- Contractor should provide monthly statement of incoming and outgoing Fire Extinguishers item wise.
- The maintenance work of fire extinguishers shall be carried out as per IS 219 0; 2010 or as the latest IS guidelines.
- Job Card for each Fire Extinguisher shall be provided.

SI. No.	Type of Fire Extinguish er	Weight	Number of Fire Extinguisher
1.	CO2	9 Kg	10
2.	CO2	6.5 Kg	20
3.	CO2	4.5 Kg	14
4.	CO2	2 Kg	12
5.	DCP	12.6 Kg	02
6.	DCP	10 Kg	31
7.	DCP	6.5 Kg	33

DETAILS OF FIRE EXTINGUISHERS



and Buyer may take suitable actions as per GeM Contract.

This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो।बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत का समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---